

Acceptable Solar Disconnect Qualifications

- MUST be a lockable disconnect with a visible point of opening
- Labeled properly
 - If disconnect is not visible or not in close proximity to meter base, a label shall be placed on meter cabinet explaining solar disconnect location.
 - Examples of acceptable PV Labels:



- Shall be accessible to field personnel (i.e. not within locked gate or a place that is hard to reach)

Examples of Approved Disconnects:

